

Coral Coast Water Connection Checklist

This checklist is a guide for customers wishing to connect to Coral Coast Water Pty Ltd's non-potable water supply for commercial or stock and garden purposes.

- Download and read the "information for customers" brochure
- Read through the Coral Coast Water Customer Service Charter.
- Fill out and lodge a Coral Coast Water application form.
- Your application will be considered by the Coral Coast Water Board of Directors subject to connection fees.
- You will be provided with a quote if your connection is non-standard.
- Sign and return the quote acceptance page to the GWC office.
- Once your application has been approved you will be issued a with a Supply Contract document.
- Read through your customer contract, sign and return to the GWC office.
- Arrange for a licenced Plumber to install a tank and backflow prevention devices signed off by a qualified plumber and certification submitted to the GWC office. See minimum Standard for connection requirements on the back of this Checklist.
- Arrange for full payment of the Invoice for the connection fee.

GWC will install your new service connection within 10 working days from completion of

- Payment for the connection; and
- Certified tank installed by Licenced Plumber; and
- Completion and return of signed Supply Contract.

All forms to be delivered to or posted to:

Coral Coast Water Pty Ltd

Physical Address: 50 Boundary Road, Carnarvon WA

Mailing Address: Po Box 5 Carnarvon WA 6701

Please return original forms. Faxed/emailed copies are not accepted.

If you have any questions please call 9941 4488

Standard Connection Requirements

The applicant is responsible for:

1. all private works – water supply pipework and fittings on the applicant's side of the meter;
2. installing a water storage tank having a minimum capacity of five thousand (5,000) litres;
3. installing a float and shut-off valve or other suitable flow control mechanism to avoid overflow from the applicant's tank;
4. installing a registered air gap in accordance with Australian and New Zealand Plumbing Standard "AS/NZ2S 3500-2003 Plumbing and Drainage" between the supply outlet and the maximum level of the applicant's tank.
5. Providing GWC with a copy of the certification that items 2 – 4 have been installed by a Licenced Plumber.